

Compliance report

EN 50155

**Qualification of Baumer Level Switch LFFS and LBFS to
Railway applications according to BS EN 50155 –
Shock and Vibration Standard EN 61373**

**(Governing Standard BS EN 50155 Railway Applications
– Electronic equipment used on rolling stock)**

Dated 2011-11-22

Contents

1.0 Statement compliant to EN50155	4
2.0 Evaluation of LFFS and LBFS according to EN50155	5
3.0 Product under test	5
4.0 Environmental service condition of operation	5
4.1.1 Altitude	5
4.1.2 Ambient temperature	5
4.1.3 Shock and vibration	8
4.1.4 Relative humidity	9
4.2 Special service conditions	11
4.2.1 Atmospheric pollutants.....	11
5.0 Electric service conditions	11
5.1 Power supply.....	11
5.1.1 Supply from accumulator.....	11
5.1.1.1 Variation of voltage supply	11
5.1.1.2 Interruption of voltage supplies	13
5.1.1.3 Variation of voltage supplies	13
5.1.1.4 D.C. ripple factor	13
5.1.2 Supply by a static converter or a rotating set.....	13
5.1.3 Supply change over	13
5.1.4 Supply with overhead line or third rail	13
5.1.5 Supply rated surges.....	14
5.2 Supply overvoltage.....	14
5.3 Installation	14
5.4 Surges and electrostatic discharge according to EN 50155 / EN50121.....	14
5.5 Electromagnetic compatibility according to EN 50155 / EN50121.....	14
6 Reliability, maintainability and expected useful life	14
6.1 Equipment reliability.....	14
6.1.1 Predicted reliability.....	14
6.1.2 Proof reliability.....	15
6.2 Useful life	16
6.3 Maintainability	16
6.4 Maintenance levels	16
6.4.1 On-vehicle diagnosis and repair.....	16
6.4.2 Off-vehicle diagnosis and repair	16
6.5 Built-in diagnostic	16
6.6 Automatic test equipment.....	16
6.7 Alternative methods for fault diagnosis	16
6.8 Purpose built test equipment special tools	17
7.0 Design.....	18
7.1 General.....	18
7.1.1 Quality management	18
7.1.2 Life Cycle	18
7.2 Detailed practices – Hardware.....	19
7.2.1 Interface.....	19
7.2.2 Fault protection	19

7.2.3 Referring power supplies	19
7.2.4 Interchangeability	19
7.2.5 Reduction of power supply voltage	19
7.2.6 Polarity reversal	19
7.2.7 Inrush currents.....	19
7.2.8 Spare capacity	19
7.3 Detailed practices – Software	19
7.3.1 General.....	19
7.3.2 Software design measures.....	20
7.3.2.1 Modular approach	20
7.3.2.2 Translator proven in use	20
7.3.2.3 Recording	20
7.3.2.4 Structured methodology.....	20
7.3.2.5 Design and coding methods.....	20
7.3.2.6 Structured programming and analysis.....	20
7.3.2.7 Programming language	20
7.3.2.8 Proven techniques	20
7.4 Equipment features	20
7.4.1 Memory checking.....	20
7.4.2 Self test	20
7.4.3 Watchdog	20
7.3.4 Error indication	20
7.4.5 Recovery.....	20
8.0 Components	21
8.1 Procurement	21
8.2 Application	21
9. Construction	21
8.1 Mechanical construction.....	21
10. Safty.....	21
11. Documentation.....	21
12. Testing	21

Appendix A - EMC test report according to EN50121, EN61326, DNV 2.4:2006

Appendix B - Shock and Vibrations test according to EN50155, EN/IEC61373

1.0 Statement compliant to EN50155

We,


Baumer A/S
Jacob Knudsens Vej 14
8230 Aabyhoej
Denmark

Tel: +45 89 31 76 11

confirm that the product Level Switch LBFS xxxx x (C) and LFFS xxxx x (C) are complying with the Railway standard of EN50155. Copy of detailed test reports is available on request from Baumer A/S.

Description of the evaluation and test are attach this statement. So are the declaration of conformity for EMC according to EN50121 and accredited Vibrations test according to EN61373.

Date: 2011-11-22

Sign: 

Kurt Møller Jensen, R&D Manager

2.0 Evaluation of LFFS and LBFS according to EN50155

This document is made for proving the validation of the railway approval according to EN50155. All test mentioned in the document are available on request from Baumer A/S. Most test reports are in the document shown with two pages of the complete report.

3.0 Product under test

The evaluation is based on the Level Switches LBFS and LFFS series. For the LBFS series was test performed on versions with plastic and metal M12 electrical connection where it is critical. On LFFS was test performed on normal version and sliding connection where it is critical. Each group was tested as outlined below to demonstrate compliance to EN 50155. Both product series was successfully tested without deterioration of performance of the products as demonstrated in the test results.

4.0 Environmental service condition of operation

4.1.1 Altitude

The Level switches LFFS and LBFS are suitable for applications up to 1200m of altitude. There is no customer for requirements exceeding 1200m of altitude.

4.1.2 Ambient temperature

Baumer internal extreme temperature test ranges from - 40°C to + 85°C and are preformed on all mentioned instruments.

Extreme temperature test performed on LBFS

The LBFS are connected to a 100 Ω resistor on the output. This will ensure that the current limit circuit are activated during the test and the maximum current are known. Measuring the output is done with a 10Kohm resistor as mentioned in the datasheet.

All measurings are performed with supply voltage of 24VDC.

PNP (16556):

	22,9 0C	85 0C	-40 0C
Vout_NC	22,44 VDC	22,62 VDC	22,20 VDC
	0 VDC	0,36 VDC	0 VDC
Iout_NC	22,80 mA	19,2 mA	25,6 mA
	0 mA	0 mA	0 mA
Vout_NO	22,40 VDC	22,56 VDC	22,14 VDC
	0 VDC	0,34 VDC	0 VDC
Iout_NO	22,80 mA	19,2 mA	25,1 mA
	0 mA	0 mA	0 mA

Active high PNP (VDC -1.5V) \pm 0.5V ; Rload 10 kOhm, 20 mA output current.

PNP unit are within the specification of the datasheet. The leak current when the output is off is below 100uA as described in the datasheet.

NPN (16558):

	22,9 0C	85 0C	-40 0C
Vout_NC	24,11 VDC	24,0 VDC	24,13 VDC
	1,99 VDC	1,58 VDC	2,13 VDC
Iout_NC	25,2 mA	21,1 mA	27,8 mA
	0 mA	0 mA	0 mA
Vout_NO	24,11 VDC	24,0 VDC	24,13 VDC
	1,83 VDC	1,45 VDC	2,11 VDC
Iout_NO	25,0 mA	21,0 mA	27,1 mA
	0mA	0 mA	0 mA

Active low NPN (-VDC +1.5V) \pm 0.5V ; Rload 10 kOhm, 20 mA output current.

The NPN version of the LBFS is fulfilling specification within the ambient temperature area -40°C to 85°C.

Extreme temperature test performed on LFFS

The temperature test was carried out for LFFS where a function test is performed as a function of supply voltage at different temperature levels for -40°C to 85°C.

Måleresultater

V _{in} (VDC)		-40°C (Medie: Sprit) (TRIGGER: 70%)		
		PNP output	NPN output	Digital output
+12		trig↑ (mm): 31 trig↓ (mm): 33	trig↑ (mm): 31 trig↓ (mm): 33	trig↑ (mm): 30 trig↓ (mm): 32
+36		trig↑ (mm): 31 trig↓ (mm): 33	trig↑ (mm): 31 trig↓ (mm): 32	trig↑ (mm): 30 trig↓ (mm): 32
-12		trig↑ (mm): 31 trig↓ (mm): 33	trig↑ (mm): 31 trig↓ (mm): 33	trig↑ (mm): 31 trig↓ (mm): 32
-36		trig↑ (mm): 31 trig↓ (mm): 33	trig↑ (mm): 31 trig↓ (mm): 33	trig↑ (mm): 31 trig↓ (mm): 32
V _{in} (VDC)		-40°C (Medie: Plexiglas klods) (TRIGGER: 82%)		
		PNP output	NPN output	Digital output
+12		trig↑: OK trig↓: OK	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK
+36		trig↑: OK trig↓: OK	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK
-12		trig↑: OK trig↓: OK	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK
-36		trig↑: OK trig↓: OK	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK
V _{in} (VDC)		23,6°C (Medie: Rå linolie) (TRIGGER: 82%)		
		PNP output	NPN output	Digital output
+12		trig↑ (mm): 26 trig↓ (mm): 29	trig↑ (mm): 24 trig↓ (mm): 28	trig↑ (mm): 25 trig↓ (mm): 28
+36		trig↑ (mm): 27 trig↓ (mm): 29	trig↑ (mm): 26 trig↓ (mm): 29	trig↑ (mm): 27 trig↓ (mm): 29
-12		trig↑ (mm): 25 trig↓ (mm): 28	trig↑ (mm): 25 trig↓ (mm): 28	trig↑ (mm): 25 trig↓ (mm): 28
-36		trig↑ (mm): 27 trig↓ (mm): 29	trig↑ (mm): 26 trig↓ (mm): 29	trig↑ (mm): 27 trig↓ (mm): 29
V _{in} (VDC)		85°C (Medie: Rå linolie) (TRIGGER: 82%)		

	PNP output	NPN output	Digital output
+12	trig↑ (mm): 12 trig↓ (mm): 16	trig↑ (mm): 12 trig↓ (mm): 16	trig↑ (mm): 11 trig↓ (mm): 15
+36	trig↑ (mm): 14 trig↓ (mm): 17	trig↑ (mm): 13 trig↓ (mm): 16	trig↑ (mm): 13 trig↓ (mm): 17
-12	trig↑ (mm): 11 trig↓ (mm): 16	trig↑ (mm): 10 trig↓ (mm): 15	trig↑ (mm): 11 trig↓ (mm): 15
-36	trig↑ (mm): 13 trig↓ (mm): 17	trig↑ (mm): 13 trig↓ (mm): 16	trig↑ (mm): 13 trig↓ (mm): 17
V_{in} (VDC)	85°C (Medie: Plexiglas klods) (TRIGGER 82%)		
	PNP output	NPN output	Digital output
+12	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK
+36	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK
-12	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK
-36	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK	trig↑: OK trig↓: OK

Supplementary temperature test

Tests for LFFS and LBFS according to IEC60945 are added as supplementary test. Test reports are made in separated documents as show below.



Process Instrumentation

Temperature test of LFFS

Scope of the test
This test serves to demonstrate that the EUT is not damage as a consequence of the Dry and cold temperature test.


Test procedure
The temperature test are carried out according to described test procedure in "ENVIRONMENTAL TEST SPECIFICATION FOR INSTRUMENTATION AND AUTOMATION EQUIPMENT" FORM April 2006. The test is split in two sections on based on 3.7 Dry Heat Test form the standard and 3.9 Cold test.

Dry Heat Test:

- The DUT must be powered on during the test/temperature period.

Test procedure:

- The temperature sequence are following below figure



TN : normal ambient temperature equal 20 to 25°C

- Main function test must be performed end of each base temperature and filled to the table below.

Test results for Dry Heat Test

Functions	T _h (20°C to 25°C)	55°C	70°C	T _h (20°C to 25°C)
Switch on (LED on)	OK	OK	OK	OK
Switch off (LED off)	OK	OK	OK	OK

Side 1 af 6 QA: KMJ Dato for sidste rev.: 2011-10-18 Dok. Nr.: 5505-108 Rev.: A1



Process Instrumentation

Nominal supply voltage are decided to be in the middle of the working supply span evaluated form the product datasheet.


Cold Test:
This test are performed according to point 3.9 in "ENVIRONMENTAL TEST SPECIFICATION FOR INSTRUMENTATION AND AUTOMATION EQUIPMENT" FORM April 2006.

Test condition:

- The DUT must be powered on during the test/temperature period.
- B

Test procedure:

- The temperature sequence are following below figure



2 h (test interval)

Main function test must be performed end of each base temperature and filled to the table below. The DUT must be powered on during the test/temperature period.

Test results Cold Test:

Functions	20°C	-25°C	20°C
Switch on (LED on)	OK	OK	OK
Switch off (LED off)	OK	OK	OK

As shown in the test results above, the test is performed successfully. Against this background it is concluded that the test is approved.

Date: 
Torben Dahl

Test engineer: 
Elbte Stig Terber

Authorized by DNV: 

Side 2 af 6 QA: KMJ Dato for sidste rev.: 2011-10-18 Dok. Nr.: 5505-108 Rev.: A1

<p>Baumer</p> <p>Process Instrumentation</p> <p>Temperature test of LBFS</p> <p>Scope of the test This test serves to demonstrate that the EUT is not damage as a consequence of the Dry and cold temperature test.</p> <p>Test procedure The temperature test are carried out according to described test procedure in "ENVIRONMENTAL TEST SPECIFICATION FOR INSTRUMENTATION AND AUTOMATION EQUIPMENT" FORM April 2006. The test are split in two sections on based on 3.7 Dry Heat Test form the standard and 3.9 Cold test.</p> <p>Dry Heat Test:</p> <p>Test condition:</p> <ul style="list-style-type: none"> - The DUT must be powered on during the test/temperature period. <p>Test procedure:</p> <ul style="list-style-type: none"> - The temperature sequence are following below figure <p>TN : normal ambient temperature equal 20 to 25°C</p> <ul style="list-style-type: none"> - Main function test must be preformed end of each base temperature and filled to the table below. <p>Test results for Dry Heat Test</p> <table border="1"> <thead> <tr> <th>Functions</th> <th>T_b (20°C to 25°C)</th> <th>55°C</th> <th>70°C</th> <th>T_b (20°C to 25°C)</th> </tr> </thead> <tbody> <tr> <td>Switch on (LED on)</td> <td>OK</td> <td>OK</td> <td>OK</td> <td>OK</td> </tr> <tr> <td>Switch off (LED off)</td> <td>OK</td> <td>OK</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table> <p>Side 1 af 5 QA: KMJ Dato for sidste rev.: 2011-10-18 Dok. Nr.: 5505-114 Rev.: A1</p>	Functions	T _b (20°C to 25°C)	55°C	70°C	T _b (20°C to 25°C)	Switch on (LED on)	OK	OK	OK	OK	Switch off (LED off)	OK	OK	OK	OK	<p>Baumer</p> <p>Process Instrumentation</p> <p>Nominal supply voltage are decided to be in the middle of the working supply span evaluated form the product datasheet.</p> <p>Cold Test: This test are performed according to point 3.9 in "ENVIRONMENTAL TEST SPECIFICATION FOR INSTRUMENTATION AND AUTOMATION EQUIPMENT" FORM April 2006.</p> <p>Test condition:</p> <ul style="list-style-type: none"> - The DUT must be powered on during the test/temperature period. - B <p>Test procedure:</p> <ul style="list-style-type: none"> - The temperature sequence are following below figure <p>Main function test must be preformed end of each base temperature and filled to the table below. The DUT must be powered on during the test/temperature period.</p> <p>Test results Cold Test:</p> <table border="1"> <thead> <tr> <th>Functions</th> <th>20°C</th> <th>-25°C</th> <th>20°C</th> </tr> </thead> <tbody> <tr> <td>Switch on (LED on)</td> <td>OK</td> <td>OK</td> <td>OK</td> </tr> <tr> <td>Switch off (LED off)</td> <td>OK</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table> <p>Conclusion As shown in the test results above, the test is performed successfully. Against this background it is concluded that the test is approved</p> <p>Date: </p> <p>Test engineer: Torben Dahl</p> <p>Authorized by DNV: Elbø Stig Terber</p> <p>Side 2 af 5 QA: KMJ Dato for sidste rev.: 2011-10-18 Dok. Nr.: 5505-114 Rev.: A1</p>	Functions	20°C	-25°C	20°C	Switch on (LED on)	OK	OK	OK	Switch off (LED off)	OK	OK	OK
Functions	T _b (20°C to 25°C)	55°C	70°C	T _b (20°C to 25°C)																								
Switch on (LED on)	OK	OK	OK	OK																								
Switch off (LED off)	OK	OK	OK	OK																								
Functions	20°C	-25°C	20°C																									
Switch on (LED on)	OK	OK	OK																									
Switch off (LED off)	OK	OK	OK																									

4.1.3 Shock and vibration

Tests of LFFS and LBFS according Requirements from IEC publication 600068-2-6 and EN 61373 were verified. Test reports are made in separated documents two pages are shown below.
Total Accredited report for fulfilling vibration and shock requirements from EN50155 and EN61373 can be seen in appendix B.

<small>DANAK-1911632 DETA-T201052 Page 2 of 18</small>							
<p>Title Vibration and shock test of Level Switches</p> <p>Test object 4 pcs. Level Switches Detailed information is given in Chapter 2.</p> <p>Report no. DANAK-1911632</p> <p>Project no. T201052</p> <p>Test period 6 – 12 October 2011</p> <p>Client Baumer A/S Joh. C. Sandstrømsvei 14 8210 Åsbyhaug Drammen Tel. +47 89 31 76 11</p> <p>Contact person Kurt Møller Jensen E-mail: kmjensen@baumer.com</p> <p>Manufacturer Baumer A/S</p> <p>Specifications EN 50155: 2007 Railway applications – Electronic equipment used on rolling stock EN/IEC 61373:1999 Railway applications – Rolling stock equipment – Shock and vibration tests</p> <p>Results The performance of the test objects was OK before and after the exposure. No change in visual appearance and mechanical integrity was observed after the exposure.</p> <p>Test personnel René Tofthol Torben Sibbern Larsen</p>							
CK/Ro	DETA						
<small>DANAK-1911632 DETA-T201052 Page 5 of 18</small>							
<p>1. Summary of test</p> <p>1.1 Test requirements The following tests were carried out as agreed with the client.</p> <table border="0" style="width: 100%;"> <tr> <td style="width: 50px;">Test</td> <td style="width: 50px;">Test method</td> </tr> <tr> <td>Random vibration</td> <td>EN/IEC 60068-2-6:2008</td> </tr> <tr> <td>Shock</td> <td>EN/IEC 60068-2-27:2008</td> </tr> </table> <p>1.2 Conclusion The test object mentioned in this report meets the relevant requirements of the standards stated below.</p> <ul style="list-style-type: none"> • EN 50155:2007 • EN 61373:1999 <p>The test results relate only to the objects tested.</p>		Test	Test method	Random vibration	EN/IEC 60068-2-6:2008	Shock	EN/IEC 60068-2-27:2008
Test	Test method						
Random vibration	EN/IEC 60068-2-6:2008						
Shock	EN/IEC 60068-2-27:2008						

 Baumer Process Instrumentation	 Baumer Process Instrumentation												
<p><u>Vibration test - LFFS and LBFS Level Switch</u></p> <p>Date: 2010-08-20</p> <p>Responsible: Kenneth Hansen, Baumer A/S</p> <p>DUT: The following devices are used under the test:</p> <div style="display: flex; justify-content: space-around; align-items: flex-end;"> <div style="text-align: center;">  1 </div> <div style="text-align: center;">  2 </div> <div style="text-align: center;">  3 </div> </div> <p>Purpose: To show the products ability to withstand vibrations.</p> <p>Test Instruments: Vibration generator</p> <p>Set up: The products process connections are fastened into welding counterparts and tightened in accordance with data from their respective datasheets:</p> <table border="0" style="width: 100%;"> <tr> <td>LFFS-034:</td> <td>28 Nm</td> </tr> <tr> <td>LFFS-031:</td> <td>22 Nm</td> </tr> <tr> <td>LBFS-01111:</td> <td>N/A</td> </tr> </table> <p>The level switches are connected to their own AC-DC adaptors and configured to be constantly activated.</p> <p>Last page: 15 Date for last rev.: 2010-08-20 Rev.: B1 <small>File name: 5505080 B1.doc QA: KHA Dok. Nr.: 5505-080 Page: 1</small> <small>Raw data: F:\U_\process\Datasheets\various\5505-5508-00 Vibration test LBFS og LFFS Level Switch\B1\Raw data\sp</small></p>		LFFS-034:	28 Nm	LFFS-031:	22 Nm	LBFS-01111:	N/A						
LFFS-034:	28 Nm												
LFFS-031:	22 Nm												
LBFS-01111:	N/A												
<p>Test conditions</p> <p>IEC 60068-2-6:2008, Specific GL test 2 High Vibrator Strain: 5 – 25 Hz: 1,6 mm peak displacement 25 – 100 Hz: 4 g acceleration Sweep rate: 1 oct/min. No. of sweeps: 10 Axis: X,Y,Z</p> <p>IEC 60068-2-6:2008, Specific GL test 2 Resonance search: Acceleration level: 0,5 g Frequency range: 5 – 1000 Hz Sweep rate: 1 oct/min. Axis: X,Y,Z</p> <p>If resonance frequencies are found below 100 Hz, the vibrator will be adjusted to these frequencies and the DUT will be committed to this vibration for at least 20 minutes.</p> <p>The units are supplied by external power and put into constant activated state which means that their LED's are also activated. The lights are monitored during the test. If a light should go out the DUT in question has failed the test. After the test, all functionalities will be checked for errors on each device.</p> <table border="0" style="width: 100%;"> <tr> <td style="width: 50px;">Last page: 15</td> <td style="width: 50px;">Date for last rev.: 2010-08-20</td> <td style="width: 50px;">Rev.: B1</td> </tr> <tr> <td>File name: 5505080 B1.doc</td> <td>QA: KHA</td> <td>Dok. Nr.: 5505-080</td> </tr> <tr> <td colspan="3" style="text-align: center;">Page: 2</td> </tr> <tr> <td colspan="3" style="text-align: center;">Raw data: F:\U_\process\Datasheets\various\5505-5508-00 Vibration test LBFS og LFFS Level Switch\B1\Raw data\sp</td> </tr> </table>		Last page: 15	Date for last rev.: 2010-08-20	Rev.: B1	File name: 5505080 B1.doc	QA: KHA	Dok. Nr.: 5505-080	Page: 2			Raw data: F:\U_\process\Datasheets\various\5505-5508-00 Vibration test LBFS og LFFS Level Switch\B1\Raw data\sp		
Last page: 15	Date for last rev.: 2010-08-20	Rev.: B1											
File name: 5505080 B1.doc	QA: KHA	Dok. Nr.: 5505-080											
Page: 2													
Raw data: F:\U_\process\Datasheets\various\5505-5508-00 Vibration test LBFS og LFFS Level Switch\B1\Raw data\sp													

Both tests fulfill the specification from the standard and are therefore approved.

4.1.4 Relative humidity

Requirements according to IEC 60068-2-30 were verified.

Concerning LFFS:

Side 9 af 21	QA: KMJ	Date for sidste rev.: 2011-11-22	Dok. Nr.: 5506-124	Rev.: A1
--------------	---------	----------------------------------	--------------------	----------

Baumer Process Instrumentation

Humidity test for LFFS

Scope of the test
This test serves to demonstrate that the EUT is not damage and no permanent or temporary malfunction occurs during a high humidity.

Damp Heat Test:
The temperature test are carried out according to described test procedure in "ENVIRONMENTAL TEST SPECIFICATION FOR INSTRUMENTATION AND AUTOMATION EQUIPMENT" FORM April 2006. The test performed in according to 3.8.1 Damp Heat Test from the standard. Furthermore are the test carried out with respect to cyclic condensation which are mandatory for class B.

Damp Heat Test:
Test condition:
- The DUT must be powered on during the test period.

Test procedure:
- Let the instrument stabilize in temperature at 25°C without power.
- Below shown test cycle must be run through 2 times. During first test cycle the unit must be switched off. The DUT must be switched on in second run. The temperature and humidity must follow the sequence shown in below figure.

The diagram shows a 24-hour test cycle. It starts with a 150% humidity period of 15 minutes, followed by a 95% humidity period of 15 minutes. This is followed by a 100% temperature period of 15 minutes, then a 95% humidity period of 15 minutes. The cycle then repeats. Below this, a temperature profile shows a ramp from 25°C to 55°C over 3 hours, a dwell at 55°C for 12 hours, a ramp down to 22°C over 3 hours, and a dwell at 22°C for 8 hours. The total cycle time is 24 hours.

End of the temperature rise Start of the temperature fall

100% 95% 95% 100% 95% 95%

15 min 15 min 15 min 15 min 15 min 15 min

Time

+55°C

+25°C

Temperature tolerance ±2°C

12 h

3 h

8 h

1 cycle = 24 hours

Side 1 af 2 QA: KMJ Dato for sidste rev.: 2011-10-18 Dok. Nr.: 5505-105 Rev.: A1

Baumer Process Instrumentation

- In second cycle must the power be switch on. Afterward same procedure at carried out again. Let the instrument stabilize in temperature at 25°C without power.
- Performance test must be carried out during the test cycle, results should be filled in below table

Test results for Dry Heat Test

Functions	High temperature (55°C) /humidity (96%)	Low temperature (25°C) /humidity (95%)	Comments
Detect of media (LED on)	OK	OK	
Detect of media (LED off)	OK	OK	

Nominal supply voltage are decided to be in the middle of the working supply span evaluated form the product datasheet.

Conclusion
As shown in the test results above, the test is performed successfully. Against this background it is concluded that the test is approved.

Test engineer: *Torben Dahl*
Authorized by DNV: *Ebbe Stig Terber*

Side 2 af 2 QA: KMJ Dato for sidste rev.: 2011-10-18 Dok. Nr.: 5505-105 Rev.: A1

Concerning LBFS :

Baumer Process Instrumentation

Humidity test for LFBS

Scope of the test
This test serves to demonstrate that the EUT is not damage and no permanent or temporary malfunction occurs during a high humidity.

Damp Heat Test:
The temperature test are carried out according to described test procedure in "ENVIRONMENTAL TEST SPECIFICATION FOR INSTRUMENTATION AND AUTOMATION EQUIPMENT" FORM April 2006. The test performed in according to 3.8.1 Damp Heat Test from the standard. Furthermore are the test carried out with respect to cyclic condensation which are mandatory for class B.

Damp Heat Test:
Test condition:
- The DUT must be powered on during the test period.

Test procedure:
- Let the instrument stabilize in temperature at 25°C without power.
- Below shown test cycle must be run through 2 times. During first test cycle the unit must be switched off. The DUT must be switched on in second run. The temperature and humidity must follow the sequence shown in below figure.

The diagram shows a 24-hour test cycle. It starts with a 150% humidity period of 15 minutes, followed by a 95% humidity period of 15 minutes. This is followed by a 100% temperature period of 15 minutes, then a 95% humidity period of 15 minutes. The cycle then repeats. Below this, a temperature profile shows a ramp from 25°C to 55°C over 3 hours, a dwell at 55°C for 12 hours, a ramp down to 22°C over 3 hours, and a dwell at 22°C for 8 hours. The total cycle time is 24 hours.

End of the temperature rise Start of the temperature fall

100% 95% 95% 100% 95% 95%

15 min 15 min 15 min 15 min 15 min 15 min

Time

+55°C

+25°C

Temperature tolerance ±2°C

12 h

3 h

8 h

1 cycle = 24 hours

Side 1 af 2 QA: KMJ Dato for sidste rev.: 2011-10-21 Dok. Nr.: 5505-111 Rev.: A1

Baumer Process Instrumentation

- In second cycle must the power be switch on. Afterward same procedure at carried out again. Let the instrument stabilize in temperature at 25°C without power.
- Performance test must be carried out during the test cycle, results should be filled in below table

Test results for Dry Heat Test

Functions	High temperature (55°C) /humidity (96%)	Low temperature (25°C) /humidity (95%)	Comments
Detect of media (LED on)	OK	OK	
Detect of media (LED off)	OK	OK	

Nominal supply voltage are decided to be in the middle of the working supply span evaluated form the product datasheet.

Conclusion
As shown in the test results above, the test is performed successfully. Against this background it is concluded that the test is approved.

Date: 2011-10-21
Test engineer: *Torben Dahl*
Authorized by DNV: *Ebbe Stig Terber*

Side 2 af 2 QA: KMJ Dato for sidste rev.: 2011-10-21 Dok. Nr.: 5505-111 Rev.: A1

4.2 Special service conditions

The products can be adjusted according to the customer needs within the limit of the product configuration possibilities. This can be done with the Flexprogram software and the configuration unit Flexprogrammer9701. Software og konfiguration enhed er ikke en del af LFFS og LBFS men tjener som service udstyr.

4.2.1 Atmospheric pollutants

Requirements according IEC 60068-2-30 Damp heat cyclic test were verified and accredited by Det Norske Veritas (DNV). See point 4.1.4

Requirements according IEC 60068-2-52 Salt mist test were verified and accredited by Delta A/S

<p style="text-align: right;">DANAK-1911536 DELTA-T200542-4 Page 2 of 13</p> <p>Title Salt mist test of 4 units Test objects 1 pc. LFFS Level Switch 1 pc. FlexBar HRT 1 pc. CombiTemp 1 pc. LBFS Level Switch Detailed information is given in Chapter 2. The test objects were received on 1 July 2011.</p> <p>Report no. DANAK-1911536 Project no. T200542 Test period 4 July - 1 August 2011 Client Baumer A/S Jacob Knudsenvej 14 8230 Abyhøj Danmark Tel.: +45 89 31 76 11 Contact person Mr. Kurt Møller Jensen E-mail: kmjensen@baumer.dk Manufacturer Baumer A/S Specifications IEC 60068-2-52 Salt mist Results Sign of spotted trace of corrosion outside the test object, No sign of corrosion was observed inside the test objects. Test personnel Andreas Wendelboe Højsgaard Jens Schoustrup Thomsen Date 23 August 2011 Prepared by  Henrik Funder Ravn, B.Sc.E.E. DELTA Responsible  Kim A. Schmidt, B.Sc.M.E. DELTA <small>HFR/kø</small> </p>	<p style="text-align: right;">DANAK-1911536 DELTA-T200542-4 Page 5 of 13</p> <p>3. Test and results</p> <p>3.1 Test requirements The following tests were carried out as agreed with the client.</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;">Test</th> <th style="width: 50%;">Test method</th> </tr> </thead> <tbody> <tr> <td>Salt mist, cyclic - corrosion</td> <td>IEC 60068-2-52:1996</td> </tr> </tbody> </table> <p>3.2 Salt mist, cyclic - corrosion</p> <p>Specification IEC 60068-2-52, severity 1.</p> <p>Severity and procedure Concentration of NaCl : 5 % pH of salt solution : 6.5 - 7.2 Number of cycles : 4 Total duration : 28 days</p> <p>The test object is installed in the salt mist chamber and sprayed with the salt mist solution for a period of 2 hours.</p> <p>At the end of the spraying period, the test object is exposed to humidity and stored at a temperature of 40 °C ±2 °C and a relative humidity of 93 % +2 / -3 % for a period of 7 days.</p> <p>The above constitutes one cycle, which is repeated three times.</p> <p>The test object is de-energised during the exposure.</p> <p>After the finalisation of the entire exposure, a visual inspection is performed.</p> <p>Results</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 33%;">Test object</th> <th style="width: 33%;">Visual outside</th> <th style="width: 33%;">Visual inside</th> </tr> </thead> <tbody> <tr> <td>LFFS Level Switch</td> <td>Sign of spotted trace of corrosion outside the test object.</td> <td>No sign of corrosion was observed inside the test object.</td> </tr> <tr> <td>FlexBar HRT</td> <td>Sign of spotted trace of corrosion outside the test object.</td> <td>No sign of corrosion was observed inside the test object.</td> </tr> <tr> <td>CombiTemp</td> <td>Sign of spotted trace of corrosion outside the test object.</td> <td>No sign of corrosion was observed inside the test object.</td> </tr> </tbody> </table> <p style="text-align: right;">HFR/kø </p>	Test	Test method	Salt mist, cyclic - corrosion	IEC 60068-2-52:1996	Test object	Visual outside	Visual inside	LFFS Level Switch	Sign of spotted trace of corrosion outside the test object.	No sign of corrosion was observed inside the test object.	FlexBar HRT	Sign of spotted trace of corrosion outside the test object.	No sign of corrosion was observed inside the test object.	CombiTemp	Sign of spotted trace of corrosion outside the test object.	No sign of corrosion was observed inside the test object.
Test	Test method																
Salt mist, cyclic - corrosion	IEC 60068-2-52:1996																
Test object	Visual outside	Visual inside															
LFFS Level Switch	Sign of spotted trace of corrosion outside the test object.	No sign of corrosion was observed inside the test object.															
FlexBar HRT	Sign of spotted trace of corrosion outside the test object.	No sign of corrosion was observed inside the test object.															
CombiTemp	Sign of spotted trace of corrosion outside the test object.	No sign of corrosion was observed inside the test object.															

5.0 Electric service conditions

5.1 Power supply

5.1.1 Supply from accumulator

The specification of the power supply voltage for LFFS is 12,5Vdc to 36Vdc. Most of the tests are carried out at 24VDC.

5.1.1.1 Variation of voltage supply


The power supply range for LFFS is specified between 12,5VDC to 36VDC while LBFS is specified to a power supply range from 12VDC and 30VDC.

For both products is the voltage supply range limited for the ATEX version.


Side 11 af 21	QA: KMJ	Dato for sidste rev.: 2011-11-22	Dok. Nr.: 5506-124	Rev.: A1
---------------	---------	----------------------------------	--------------------	----------

Requirements according Det Norske Veritas (DNV). were verified in below test reports.

LFFS:

<div style="border: 1px solid black; padding: 10px;"> <p>Baumer Process Instrumentation</p> <p>Power supply variations test</p> <p>Scope of the test</p> <p>This test serves to demonstrate that in case of power supply variations, no damage is caused to restoration of the power supply don't damage to the instrument.</p> <p>Test procedure</p> <p>The Power supply variations test are carried out according to described test procedure in "ENVIRONMENTAL TEST SPECIFICATION FOR INSTRUMENTATION AND AUTOMATION EQUIPMENT" FORM April 2006 part 1.5.1 with following description:</p> <p>Test conditions:</p> <ul style="list-style-type: none"> - Power up the instrument at nominal supply and wait for stabilized working condition. - The DUT are designed DC voltage which means frequency variations are left out. According to the test spec. <p>Test procedure:</p> <ul style="list-style-type: none"> - Vary supply voltage $\pm 10\%$ from nominal supply voltage within 15 minutes interval. - Vary supply voltage $\pm 20\%$ from nominal supply voltage within 1.5 minutes interval. <p>Nominal supply voltage are decided to be in the middle of the working supply span evaluated from the product datasheet.</p> <p>Test results</p> <p>Name of DUT : LFFS XXX (C)</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Low (-10% @ test 1 and -20% @ test 2)</th> <th>High ((10% @ test 1 and 20% @ test 2)</th> <th>comments</th> </tr> </thead> <tbody> <tr> <td>Test 1 15 minutes interval</td> <td>Ok</td> <td>Ok</td> <td>Test performed at 24Vdc nominal</td> </tr> <tr> <td>Test2 1.5 minutes interval</td> <td>Ok</td> <td>Ok</td> <td>Test performed at 24Vdc nominal</td> </tr> </tbody> </table> <p>test value (10% or 20%)</p>  <p>Interval time : 15 minutes or 1.5 minutes</p> <p>Nominal supply</p> <p>test value (-10% or -20%)</p> <p>Interval time : 15 minutes or 1.5 minutes</p> <p>Side 1 af 2 QA: KMJ Data for sidste rev.: 2011-10-18 Dok. Nr.: 5505-107 Rev.: A1</p> </div>		Low (-10% @ test 1 and -20% @ test 2)	High ((10% @ test 1 and 20% @ test 2)	comments	Test 1 15 minutes interval	Ok	Ok	Test performed at 24Vdc nominal	Test2 1.5 minutes interval	Ok	Ok	Test performed at 24Vdc nominal	<div style="border: 1px solid black; padding: 10px;"> <p>Baumer Process Instrumentation</p>  <p>Conclusion</p> <p>As shown in the test results above, the test is performed successfully. Against this background it is concluded that the test is approved</p> <p>Date: 2011-10-18</p> <p>Test engineer:  Torben Dahl</p> <p>Authorized by DNV:  Ebbe Stig Terber</p> <p>Side 2 af 2 QA: KMJ Data for sidste rev.: 2011-10-18 Dok. Nr.: 5505-107 Rev.: A1</p> </div>
	Low (-10% @ test 1 and -20% @ test 2)	High ((10% @ test 1 and 20% @ test 2)	comments										
Test 1 15 minutes interval	Ok	Ok	Test performed at 24Vdc nominal										
Test2 1.5 minutes interval	Ok	Ok	Test performed at 24Vdc nominal										

LBFS:

<div style="border: 1px solid black; padding: 10px;"> <p>Baumer Process Instrumentation</p> <p>Power supply variations test</p> <p>Scope of the test</p> <p>This test serves to demonstrate that in case of power supply variations, no damage is caused to restoration of the power supply don't damage to the instrument.</p> <p>Test procedure</p> <p>The Power supply variations test are carried out according to described test procedure in "ENVIRONMENTAL TEST SPECIFICATION FOR INSTRUMENTATION AND AUTOMATION EQUIPMENT" FORM April 2006 part 1.5.1 with following description:</p> <p>Test conditions:</p> <ul style="list-style-type: none"> - Power up the instrument at nominal supply and wait for stabilized working condition. - The DUT are designed DC voltage which means frequency variations are left out. According to the test spec. <p>Test procedure:</p> <ul style="list-style-type: none"> - Vary supply voltage $\pm 10\%$ from nominal supply voltage within 15 minutes interval. - Vary supply voltage $\pm 20\%$ from nominal supply voltage within 1.5 minutes interval. <p>Nominal supply voltage are decided to be in the middle of the working supply span evaluated from the product datasheet.</p> <p>Test results</p> <p>Name of DUT : LBFS XXXX x (S)</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Low (-10% @ test 1 and -20% @ test 2)</th> <th>High ((10% @ test 1 and 20% @ test 2)</th> <th>comments</th> </tr> </thead> <tbody> <tr> <td>Test 1 15 minutes interval</td> <td>Ok</td> <td>Ok</td> <td>Test performed at 24Vdc nominal</td> </tr> <tr> <td>Test2 1.5 minutes interval</td> <td>Ok</td> <td>Ok</td> <td>Test performed at 24Vdc nominal</td> </tr> </tbody> </table> <p>test value (10% or 20%)</p>  <p>Interval time : 15 minutes or 1.5 minutes</p> <p>Nominal supply</p> <p>test value (-10% or -20%)</p> <p>Interval time : 15 minutes or 1.5 minutes</p> <p>Side 1 af 2 QA: KMJ Data for sidste rev.: 2011-10-18 Dok. Nr.: 5505-113 Rev.: A1</p> </div>		Low (-10% @ test 1 and -20% @ test 2)	High ((10% @ test 1 and 20% @ test 2)	comments	Test 1 15 minutes interval	Ok	Ok	Test performed at 24Vdc nominal	Test2 1.5 minutes interval	Ok	Ok	Test performed at 24Vdc nominal	<div style="border: 1px solid black; padding: 10px;"> <p>Baumer Process Instrumentation</p>  <p>Conclusion</p> <p>As shown in the test results above, the test is performed successfully. Against this background it is concluded that the test is approved</p> <p>Date: 2011-10-18</p> <p>Test engineer:  Torben Dahl</p> <p>Authorized by DNV:  Ebbe Stig Terber</p> <p>Side 2 af 2 QA: KMJ Data for sidste rev.: 2011-10-18 Dok. Nr.: 5505-113 Rev.: A1</p> </div>
	Low (-10% @ test 1 and -20% @ test 2)	High ((10% @ test 1 and 20% @ test 2)	comments										
Test 1 15 minutes interval	Ok	Ok	Test performed at 24Vdc nominal										
Test2 1.5 minutes interval	Ok	Ok	Test performed at 24Vdc nominal										

5.1.1.2 Interruption of voltage supplies

LFFS comply to Class S1, means no interruption of the supply voltage available according to EN50155. This is only true in worst case

LFFS:

#	Beskrivelse	Test	Status
<u>8. Power Supply interruption</u>	Test according to IEC 770 At supply interruption must the product shown correct condition immediately after the interruption. In case of restart of the product must the unstable condition be equal to the starting up time.	Output : short cut (Absolute worst case is with a short cut of the output)	2 ms: OK 4 ms: Restarts only during measuring. >4 ms: restarts

LBFS:

#	Beskrivelse	Test	Status
<u>8. Power Supply interruption</u>	Test according to IEC 770 At supply interruption must the product shown correct condition immediately after the interruption. In case of restart of the product must the unstable condition be equal to the starting up time.	Output : short cut	2 ms: OK 4 ms: Restarts only during measuring. >4 ms: restarts

5.1.1.3 Variation of voltage supplies

The requirement of this point concerns power supply units and therefore not applicable for the LFFS and LBFS series.

5.1.1.4 D.C. ripple factor

The requirement of this point concerns power supply units and therefore not applicable for the LFFS and LBFS series.

5.1.2 Supply by a static converter or a rotating set

See test performed in 5.1.1.1.

5.1.3 Supply change over

The LBFFS and LBFS comply to class C1, which means a power supply reduction to $0.6 \times U_n$ during 100ms. A class C2 of power supply changeover would generate a power restart of device T400 series. But no failure can be generated in that case.

5.1.4 Supply with overhead line or third rail

The requirement of this point is not applicable for the LFFS and LBFS series.

5.1.5 Supply rated surges

This requirement is part of voltage supply variation, see point 5.1.1.1

Requirements according to IEC EN 61000-4-2 DNV: 60068-2-30 was verified.

5.2 Supply overvoltage

This requirement is part of voltage supply variation, see point 5.1.1.1

5.3 Installation

The installation requirements are defined in manual for LFFS or LBFS.

For detailed description see operating manual for each product.

5.4 Surges and electrostatic discharge according to EN 50155 / EN50121

Requirements according EN50121 was verified. For test result see report in appendix A

5.5 Electromagnetic compatibility according to EN 50155 / EN50121

Requirements according EN50121 was verified. For test result see report in appendix A

6 Reliability, maintainability and expected useful life

6.1 Equipment reliability

6.1.1 Predicted reliability

MTTF calculations for LFFS and LBFS are carried out as show below:

Typ designation:**LFFS Level Switch**

Operating temperature [°C] 40

Operating voltage range [VDC] 12,5 - 36

EN ISO 13849-1:2007

Calculation base:

Part Count

Calculation method

Factor 10

MTTF(d)-Components (Worst Case)

Factor 0.5

50% hazardous failures

Environment temperature [°C] 40

Nominal load

Operating conditions

MIL-HDBK 217F, Notice 2 / RDF 2000

MTTF-base values (remaining parts)

Environmental conditions

Ground fixed, 40°C (Industry standard)

Conditions

constant failure rate

Total	Worst case
Mean time to dangerous failure MTTF(d) [year]	>100
Mean time to dangerous failure MTTF(d) [hours, h]	876'000
Probability of a dangerous failure per hours [1/h]	< 1.14E-06

Remarks:

- The values of applicable EN-ISO calculation method refers to worst case conditions, which are improved by factor 2 compared to calculation according to MIL-HDBK-217.
- Typical values by considering of effective applications can be improved up to factor 5.

- The resulting MTTF(d) values judges not the safety of the product. It is a calculation or estimation of the random failures, which causing based on random hardware failures as a result of limited reliability of components.

Typ designation:

Operating temperature [°C] 40
 Operating voltage range [VDC] 12 - 30
 Calculation base:
 Calculation method
 MTTF(d)-Components (Worst Case)
 50% hazardous failures
 Environment temperature [°C] 40
 Operating conditions
 MTTF-base values (remaining parts)
 Environmental conditions
 Conditions

LBFS Level Switch

EN ISO 13849-1:2007
 Part Count
 Factor 10
 Factor 0.5
 Nominal load
 MIL-HDBK 217F, Notice 2 / RDF 2000
 Ground fixed, 40°C (Industry standard)
 constant failure rate

Total	Worst case
Mean time to dangerous failure MTTF(d) [year]	>90
Mean time to dangerous failure MTTF(d) [hours, h]	788'400
Probability of a dangerous failure per hours [1/h]	< 1.27E-06

Remarks:

- The values of applicable EN-ISO calculation method refers to worst case conditions, which are improved by factor 2 compared to calculation according to MIL-HDBK-217.
- Typical values by considering of effective applications can be improved up to factor 5.
- The resulting MTTF(d) values judges not the safety of the product. It is a calculation or estimation of the random failures, which causing based on random hardware failures as a result of limited reliability of components.

6.1.2 Proof reliability

MTBF calculations for LFFS and LBFS are carried out as show below:

LFFS:

The foundation of the used MTBF calculation method is “The Field Data Measurement”
 The interpretation of registered failure has been evaluated with respect to the nature of the malfunction which was discovered in the data gathering period. Some of the distinctively failures was, measurings gives rise to a wrong output, wrong start up or an incorrect function during configuration. Inappropriate handling which could cause fault has not been taken into consideration.

Conditions for the calculation:

It is assumed that the Level Switch LFFS works continually to perform level detection in the data gathering period, the ambient temperature is 25°C.

In the MTBF calculation is a year corresponding to 8.760 hours in one year. The data gathering period during this calculation has been 39 weeks.

Furthermore, following considerations have been taken in to account, 85% of sold transmitters are actually installed and fully operation. 90% of failed products in the test period are returned for the factory for repair, the rest have not been return or are still waiting for being returned.

Annual Failure Rate [%]	0,975
MTBF [years]	102
MTBF [Hour]	897.652

LBFS:

The foundation of the used MTBF calculation method is “The Field Data Measurement”

The interpretation of registered failure has been evaluated with respect to the nature of the malfunction which was discovered in the data gathering period. Some of the distinctively failures was, measurings gives rise to a wrong output, wrong start up or an incorrect function during configuration. Inappropriate handling which could cause fault has not been taken into consideration.

Conditions for the calculation:

It is assumed that the Level Switch LBFS works continually to perform level detection in the data gathering period, the ambient temperature is 25°C.

In the MTBF calculation is a year corresponding to 8.760 hours in one year. The data gathering period during this calculation has been 46 weeks.

Furthermore, following considerations have been taken in to account, 80% of sold transmitters are actually installed and fully operation. 90% of failed products in the test period are returned for the factory for repair, the rest have not been return or are still waiting for being returned.

Annual Failure Rate [%]	0,3595
MTBF [years]	278
MTBF [Hour]	2.436.823

6.2 Useful life

Baumer A/S confirms that 20 years as useful life duration. This expectation is made on background of calculation made in 6.1.1.

6.3 Maintainability

The Level Switch LFFS and LBFS have no maintenance requirements as long as they are not exposed to medias that PEEK and the used stainless steel cannot resist.

6.4 Maintenance levels

6.4.1 On-vehicle diagnosis and repair

For some versions of the Level Switch LFFS and LBFS there a blue indication light for showing if it is triggered. Both product can be tested and configured with the Flexprogram and Flexprogrammer9701,. For details see operation manual.

6.4.2 Off-vehicle diagnosis and repair

Both LFFS and LBFS can be tested and configured with the Flexprogram and Flexprogrammer9701. On extra power are necessary. For details see operation manual.

6.5 Built-in diagnostic

There is no build-in option for diagnostic on the fly. When the product is power off the functionality can be tested with the Flexprogram and Flexprogrammer9701. For details see operation manual.

6.6 Automatic test equipment

Both products can be tested and configured with the Flexprogram and Flexprogrammer9701. For details see operation manual.

6.7 Alternative methods for fault diagnosis

Both products can be tested and configured by the Flexprogram and Flexprogrammer9701. For details see operation manual.

6.8 Purpose built test equipment special tools


The Flexprogram and Flexprogrammer9701 can be ordered at Baumer. The software can be downloaded free from www.Baumer.com.

7.0 Design

7.1 General

7.1.1 Quality management

Certificate DS/EN ISO 9001:2008:



7.1.2 Life Cycle

The product life cycle are described in the quality system which covers the process from design to scrap.

7.2 Detailed practices – Hardware

7.2.1 Interface

All circuits are tested to meet requirements from actual norms regarding EMC immunity and emission. All tests are documented as shown in appendix A. There are not galvanic isolation build in the electrical construction. However there is not contact between the media and the electrical parts.

The principals used for level measurement do not involve moving part for measured the level of the media. This ensures mechanical stability.

The allowed power supply voltage is below 60VDC/AC which means the European guideline 73/23/EWG is not applicable for those instruments.

7.2.2 Fault protection

The LFFS and LBFS are protected against permanent reverse polarity of the power lines in the voltage domain defined by the supply voltage range.

A change or restoring can be done by the configuration unit Flexprogrammer9701. Teach-in can also be performed without configuration unit, see the manual.

7.2.3 Referring power supplies

Not applicable, this is a requirement for power supplies.

7.2.4 Interchangeability

Not applicable, these requirement concern modular systems which contain single replaceable elements.

7.2.5 Reduction of power supply voltage

The LFFS and LBFS will not be damage by reducing power supply voltage. If power supply voltage drops below specified supply voltage will cause a reset of the microcontroller. The microcontroller will rise again in the power supply will reset and started again if supply raises again.

7.2.6 Polarity reversal

LFFS and LBFS are protected against permanent reversed polarity.

7.2.7 Inrush currents

No inrush current occurs with LFFS and LBFS.

7.2.8 Spare capacity

Adaption of user demands can be implemented on request. Product Firmware can be change on user location.

7.3 Detailed practices – Software

7.3.1 General

The design phase is part of the company quality system according to ISO9001, which ensures a model where each phase in the product development procedure from specification to integration is described. This procedure covers hardware as well as software development and ensures a uniform development procedure where each step is documented.

The two instruments LFFS and LBFS are both able to be firmware updated in case on maintenance. This also ensures the possibility for adaption of user demands if needed on site. The firmware update can be carried out by the customer them self with the Flexprogrammer9701. Newest firmware will always be available for downloaded on Baumer WEB.

7.3.2 Software design measures

7.3.2.1 Modular approach

The firmware is made in a modular way to ensure that the complexity doesn't prevent systematic testing and maintenance.

7.3.2.2 Translator proven in use

For the product isn't a translator applicable.

For the configurations tools, Flexprogram, can be applied in several languages. For translations to the customers language a translator can be applied.

7.3.2.3 Recording

All documentation from product design phase is made to meet demands of the quality system.
It is not applicable with a translator for LFFS and LFFS

7.3.2.4 Structured methodology

Checklists are worked out according to the procedure 5509-353 of Baumer A/S ISO9001 quality system.

7.3.2.5 Design and coding methods

Design of the code is done according to best practice and to ensure a test can be performed.

7.3.2.6 Structured programming and analysis

See point 7.3.2.5.

7.3.2.7 Programming language

High level language as C is used where it is possible. This ensures fast and sure maintenance.

7.3.2.8 Proven techniques

Proven techniques which has been used for software development and process are

- Function block diagrams
- sequence diagrams
- data flow diagrams
- decision tables
- process simulation

7.4 Equipment features

7.4.1 Memory checking

All memory are located onboard the microcontroller which helps to ensure full functionality.

7.4.2 Self test

There are not implemented self test routines to the products. However test can be performed by using the diagnostic routine from the Flexprogam.

7.4.3 Watchdog

Watchdog is build-in the product. Additional will code processing outside defined code area initiate a reset of the product. This is only applicable for Firmware version 11.

7.3.4 Error indication

Error indication is implemented by indicating an error by blinking with the LEDs.

7.4.5 Recovery

Recovery is ensured as described in point 7.4.3 Watchdog.

Side 20 af 21	QA: KMJ	Dato for sidste rev.: 2011-11-22	Dok. Nr.: 5506-124	Rev.: A1
---------------	---------	----------------------------------	--------------------	----------

8.0 Components

8.1 Procurement

All component used in the product are specified with details as supplier and product code number.

8.2 Application

The product will fulfill requirement as long as the products are used for dedicated applications as level measurement and if all data have been taken into consideration.

9. Construction

8.1 Mechanical construction

The principal used in LFFS and LBFS ensure that no mechanical stress occurs as a consequence of no moving parts. However, attention should be given to the specification of the PEEK tip and stainless steel in connection with the media and environment where the product should work.

10. Safety

11. Documentation

These requirements are covered by the Baumer Quality Management System according to EN ISO 9001.

12. Testing

State of validation of Baumer Level Switch LFFS and LBFS series referring to the test list according to EN 50155:

Ref.	Test	type	Comment
1	Visual inspection	Applied	Applied during daily work
2	Performance test	Applied	Test procedure is performed on each product during production
3	Cooling test	Applied	IEC 60068-2-1, approved by DNV
4	Dry Heat test	Applied	IEC 60068-2-2 approved by DNV
5	Damp heat test, cycle	Applied	IEC 60068-2-3 approved by DNV
6	Supply overvoltage	Applied	Performed according to specifications of DNV, Approved by DNV
7	Surges, electrostatic discharge and transient burst susceptibility	Applied	According to EN50121, EN 61326 Test is performed on Delta A/S test site
8	Radio interference test	Applied	According to DNV test spec. (156MHz to 165Mhz)
9	Insulation test	Applied	Performed according to specifications of DNV, Approved by DNV
10	Salt mist test	Applied	IEC 60068-2-52, accredit by Delta A/S
11	Vibration, shock and bump test	Applied	IEC 60068-2-6, GL test2 EN61373/EN50155, accredit by Delta A/S
12	Water tightness test	Applied	IP67 accredit test performed by Delta A/S
13	Equipment stress test		
14	Low temperature storage test	Applied	-50°C, tested locally at Baumer

Appendix A

EMC test for LFFS and LBFS

First version: A1, 2009-06-11

EMC specification of product LFFS Level Switch

- 1. Introduction**
- 2. The product**
- 3. Relevant standards**
- 4. Test plan**
- 5. Definition of error criterions**

1. Introduction**1.1 Aim:**

To set up minimum requirements to meet the protection requirements in the EMC directive 2004/108/EC

2. The product**2.1 The product:**

Level switch with a NPN, PNP or digital output.

2.2 Type:

Product type no. LFFS Level Switch

2.3 Environmental use:

Industry.

2.4 **Description of the product:**

Construction:

The product contains a circuit board, built into a round plastic cabinet mounted in a ø55 metal housing. The module contains analogue circuits and a low power CPU circuits.

The module has the following ports:

- Voltage supply input, 12-36 VDC and Flex programming (two terminals).
- Output (NPN, PNP or Digital out)

Adjustments:

The product has been adjusted from factory.

Accuracy:

Must be able to detect media with a DK value as low as 1,5.

3. **Relevant standards**

3.1 **Emission: EN 61326**

The following tests are estimated to be relevant:

- CISPR 16 and 16-1: Emission.

3.2 **Immunity: EN 61326**

The following tests are estimated to be relevant:

- EN 61000-4-2: ESD discharge 4/4 kV. Criterion B.
- EN 61000-4-3: HF field, 80 - 1000 MHz, 80% AM (10 V/m) and 1,4 - 2GHz, 80% AM, (3 V/m). Criterion A.
- EN 61000-4-4: Burst transients 1 kV CM. Criterion B.
- EN 61000-4-5: Surge transients 0,5 kV line to ground. Criterion B.
- EN 61000-4-6: Conducted HF, 0,15 - 80 MHz, 80% AM, 3 VRMS. Criterion A.

(+), (-) and the output port are defined as: "I/O signal/control connected directly to mains supply". This definition is used because a power supply unit might be connected to these ports. The teach in port is defined as an "I/O signal/control" port because it is not meant for power supply connection. Teach-In is initiated by shorting the port to the (-) terminal.

4. Test plan

4.1 The unit is programmed for PNP output to begin with. The unit output is changed to NPN and Digital out when needed.

5. Error criterions**5.1 Criterion A:**

The product is unaffected during the test, within the specified levels.

5.2 Criterion B:

The output of the product varies beyond the specified range during test, but returns to normal operation after disturbance is removed. No reset or crash is allowed.

5.3 Criterion C:

Not relevant.

DECLARATION OF CONFORMITY

We,

Baumer A/S
Jacob Knudsens Vej 14
8230 Aabyhøj
Denmark

Tel: +45 89 31 76 11

declare under our sole responsibility that the product

Product Name: **LFFS Level Switch**

Product Description: **Level switch with LED indication and PNP, NPN and Digital output
adjustments possible**

Product Type: **Level Switch**

to which this declaration relates is in conformity with
the following European Directives:

2004/108/EC

And related European Standards.

EN 61 326 Issue 1. 2006-11-03

Date 17-08-2010

Sign Kurt M. Jensen

Kurt Moeller Jensen

Development Manager

Side 5 af 5	QA: KHA	Date for last rev.: 2010-08-16	Dok. Nr.: 55 06-110	Rev.: C1
-------------	---------	--------------------------------	---------------------	----------

First version: A1, 2010-04-21

EMC specification of product LBFS Level Switch

- 1. Introduction**
- 2. The product**
- 3. Relevant standards**
- 4. Test plan**
- 5. Definition of error criterions**

1. Introduction**1.1 Aim:**

To set up minimum requirements to meet the protection requirements in the EMC directive 2004/108/EC, as well as other directives that are determined to be relevant:

EN50121-3-2:2007

DNV 2.4:2006

2. The product**2.1 The product:**

A NPN or PNP level switch with normally open and normally closed outputs

2.2 Type:

Product type no. LBFS Level Switch

2.3 Environmental use:

Industry.

2.4 Description of the product:

Construction:

The product contains a circuit board mounted in a “cylindrical” metal housing. The product is electrically connected by either a M12 or a standard four wire cable. The module contains analogue circuits and a low power CPU circuits.

The module has the following ports:

- Voltage supply input, 12-30 VDC and Flex programming (two terminals).
- Two outputs: NO and NC. The LBFS will be produced with either PNP or NPN output configuration.

Adjustments:

The product has been adjusted from factory.

Accuracy:

Must be able to detect media with a DK value as low as 1,5.

3. Relevant standards

3.1 Emission: EN 55011

The following tests are estimated to be relevant:

EN55011:2007: Conducted and radiated emission.
DNV 2,4:2006: Special requirement: 156 – 165 MHz Emergency frequency band

3.2 Immunity: EN 61326

The following tests are estimated to be relevant:

- EN 61000-4-2: ESD discharge 8/8 kV. Criterion B.
- EN 61000-4-3: HF field, 80 - 1000 MHz, 80% AM (20 V/m) and 1 – 2,5GHz, 80% AM, (10 V/m). Criterion A.
- EN 61000-4-4: Burst transients 2 kV CM. Criterion B.
- EN 61000-4-5: Surge transients 1 kV line to line, 2 kV line to ground. Criterion B.
- EN 61000-4-6: Conducted HF, 0.15 - 80 MHz, 80% AM, 10 VRMS. Criterion A.

(+), (-) and the output ports are defined as: “I/O signal/control connected directly to mains supply”. This definition is used because a power supply unit might be connected to these ports.

3.3 DNV classification

This product is classified for use on open deck (Class B) as defined in the DNV 2.4:2006 directive Table 2-1.

4. Test plan

4.1 A NPN and a PNP unit, mounted in a G½" stainless steel housing, will be tested. The units will be electrical connected via a M12 cable

5. Error criterions**5.1 Criterion A:**

The product is unaffected during the test, within the specified levels.

5.2 Criterion B:

The output of the product varies beyond the specified range during test, but returns to normal operation after disturbance is removed. No reset or crash is allowed.

5.3 Criterion C:

Not relevant.

Side 4 af 5	QA: THH	Date for last rev.: 2011-11-07	Dok. Nr.: 55 06-115	Rev.: C1
-------------	---------	--------------------------------	---------------------	----------

DECLARATION OF CONFORMITY

We,

Baumer A/S
Jacob Knudsens Vej 14
8230 Aabyhoj
Denmark

Tel: +45 89 31 76 11

declare under our sole responsibility that the product

Product Name: **LBFS Level Switch**

Product Description: **Level switch, PNP or NPN outputs, with LED indication.**

Product Type: **Level Switch**

to which this declaration relates is in conformity with
the following European Directives:

2004/108/EC

And related European Standards:

EN 61 326 Issue 1. 2006-11-03

We also declare conformity with the following specific Directives:

DNV 2.4: 2006 **The Norwegian Veritas:**
STANDARD FOR CERTIFICATION No. 2.4
ENVIRONMENTAL TEST SPECIFICA-
TION FOR INSTRUMENTATION AND
AUTOMATION EQUIPMENT

EN50121: 2006 **Railway applications – Electromagnetic compatibility – Part 3-2:**
Rolling stock apparatus

Date: 7/11-2011 Sign: Kurt M. Jensen
R&D Manager
Kurt Møller Jensen

Side 5 af 5	QA: THH	Date for last rev.: 2011-11-07	Dok. Nr.: 55 06-115	Rev.: C1
-------------	---------	--------------------------------	---------------------	----------

Appendix B

Vibrations test EN50155 / EN61373

DELTA Test Report



Vibration and shock test of Level Switches

Performed for Baumer A/S

DANAK-1911632

Project no.: T201052

Page 1 of 18

including 4 annexes

24 October 2011

DELTA
Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. (+45) 72 19 40 00
Fax (+45) 72 19 40 01
www.delta.dk

Title	Vibration and shock test of Level Switches
Test object	4 pcs. Level Switches Detailed information is given in Chapter 2.
Report no.	DANAK-1911632
Project no.	T201052
Test period	6 – 12 October 2011
Client	Baumer A/S Jakob Knudsensvej 14 8230 Åbyhøj Danmark Tel. +45 89 31 76 11
Contact person	Kurt Møller Jensen E-mail: kmjensen@baumer.com
Manufacturer	Baumer A/S
Specifications	EN 50155: 2007 Railway applications – Electronic equipment used on rolling stock. EN/IEC 61373:1999 Railway applications – Rolling stock equipment – Shock and vibration tests.
Results	The performance of the test objects was OK before and after the exposures. No change in visual appearance and mechanical integrity was observed after the exposures.
Test personnel	René Toftdal Torben Sibbern Larsen

Date 24 October 2011

Project manager



Claus Kirk, B.Sc. ME, M.Sc. AVD
Specialist, Centre of Test Excellence
DELTA

Responsible



Andreas Wendelboe Højsgaard
Specialist, Centre of Test Excellence
DELTA

Table of contents

	Page
1. Summary of test	5
1.1 Test requirements	5
1.2 Conclusion	5
2. Test objects	6
2.1 Test objects	6
2.2 Auxiliary equipment	6
3. General test conditions	7
3.1 Test setup	7
3.2 Test sequence	7
3.3 Criteria for compliance	7
3.4 Functional test	7
4. Test and results	8
4.1 Vibration – Endurance random	8
4.2 Shock	9
Annex 1 List of instruments	10
Annex 2 Photos of test setup	12
Annex 3 Measurement curves - Vibration	15
Annex 4 Measurement curves – Shock	17

1. Summary of test

1.1 Test requirements

The following tests were carried out as agreed with the client.

Test	Test method
Random vibration	EN/IEC 60068-2-64:2008
Shock	EN/IEC 60068-2-27:2008

1.2 Conclusion

The test object mentioned in this report meets the relevant requirements of the standards stated below.

- EN 50155:2007
- EN 61373:1999

The test results relate only to the objects tested.

2. Test objects

2.1 Test objects

EUT #1	Level Switch LFFS 011	S/N: 24641
EUT #2	Level Switch LFFS 014	S/N: 25610
EUT #3	Level Switch LBFS 0112 1	S/N: 24682
EUT #4	Level Switch LBFS 0312 1	S/N: 25615

EUT #3 was fitted with a plastic connector receptacle and EUT #4 was fitted with a steel receptacle.

2.2 Auxiliary equipment

Power supplies delivered by the client were used for functional tests.

3. General test conditions

3.1 Test setup

Photos describing the test setup are enclosed in Annex 2.

3.2 Test sequence

The tests were performed in the following order:

Exposure	EUT #1 and #2	EUT #3 and #4
Shock	Y	X
Random vibration	Y	X
Random vibration	X	Z
Shock	X	Z
Random vibration	Z	Y
Shock	Z	Y

3.3 Criteria for compliance

Performance criterion A: Performance according to EN/IEC 61373 section 6.3.3 remains within the defined limits.

Performance criterion B: Function according to EN/IEC 61373 6.3.2 remains within the defined limits.

Performance criterion C: The visual appearance and mechanical integrity has not changed.

3.4 Functional test

A functional test was performed before, during and after each test.

The test consisted of manually triggering the level switches and observing a blue LED indicating that the switch had been triggered and that the EUT was working.

On EUT #3 with the steel receptacle observing the LED was not possible. Instead a change in voltage between the output pins was measured using a voltmeter.

4. Test and results

4.1 Vibration – Endurance random

Specifications

EN 50155:2007

EN/IEC 61373:1999

Test method

IEC 60068-2-64: 2008, Test Fh: Vibration, broadband random and guidance.

Severity and procedure

Frequency range:	5 – 150 Hz
Acceleration spectral:	5 – 20 Hz: $0.019 \text{ g}^2/\text{Hz}$
Density: 20 – 150 Hz:	-6 dB/octave
Total RMS level:	0.79 g
Duration:	300 minutes per axis
Number of axes:	3 mutually perpendicular

A functional test was performed before and after the exposure in each axis at a vibration level of -18 dB (0.1 grms).

The test object is de-energised during the exposure to the endurance vibration levels.

A performance test is performed before and after the exposure.

A visual inspection is performed after the exposure.

Results

The function of the test objects was OK during the functional tests performed at 0.1 grms in each axis.

The performance of the test objects was OK before and after the exposure to 0.79 grms in each axis.

No change in visual appearance and mechanical integrity was observed after the exposures.

Exposure curves and definition of axes are enclosed in Annex 3.

4.2 Shock

Specifications

EN 50155:2007

EN/IEC 61373:1999

Test method

EN/IEC 60068-2-27: 2008, Test Ea and guidance: Shock.

Severity and procedure

Shock pulse: Half sine, 5 g, 30 ms

Number of directions: Each direction of 3 mutually perpendicular axes

Number of shocks: 3 per direction (18 in total)

The test object is de-energised during the exposure. A functional test is performed after each axis.

Results:

The performance of the test objects was OK before and after the exposure to 5 g, 30 ms in each axis.

No change in visual appearance and mechanical integrity was observed after the exposures.

Exposure curves are enclosed in Annex 4.

Annex 1

List of instruments

List of instruments

V01020	Shaker	LDS	V850-440 LPT 750 Combo
V01027	Shaker control system	LDS Dactron	Laser USB LAS 200
V01024	Accelerometer	Kistler	8702B500M1
V01041	Accelerometer	Kistler	8778A500

Annex 2

Photos of test setup






Photo 2. X-axis for EUT 1 & 2, Z-axis for EUT 3 & 4.







Photo 3. Z-axis for EUT 1 & 2, Y-axis for EUT 3 & 4.

Annex 3

Measurement curves - Vibration



Annex 4
Measurement curves – Shock



Graph 2 and3.

EUT #1 and #2 Y-axis

EUT #3 and #4 X-axis

Graphs in the 3 other axis are similar.